

CLEARANCE STATEMENT

CLIENT: El Paso Independent School District

PROJECT NAME: Coronado High School

LOCATION: Building B

DATE: October 05, 2018

This Environmental Statement is to certify that Building "B" located at Coronado High School in El Paso, Texas was under an asbestos abatement project. The purpose of this project was the removal of Asbestos Containing floor tile, floor tile mastic, pipe insulation, transite chalkboards and transite table tops. A Negative Pressure Enclosure (NPE) was built at above mentioned area. Asbestos abatement was performed in accordance with all applicable Federal and State Regulations and following the Technical Specifications for this specific Project. The Asbestos Abatement Contractor involved in this Project was Border Demolition and Environmental.

The final visual inspection was performed by the Project Manager delegated by the Asbestos Consultant.

PCM Clearance air sampling was conducted, using aggressive methods, after a final visual inspection and results were <0.005 f/cc for all clearance samples, which are below the EPA's clearance level of 0.01 f/cc. This area therefore can be re-occupied.

Asbestos Project Manager:

Oscar E. Ayala

Asbestos Consultant:

5620 Gateway East Blvd. F1 Paso, Texas 79905 Phone: 915-779-6605 Fax: 915-779-6689