



## CLEARANCE STATEMENT

CLIENT: El Paso Independent School District.

PROJECT NAME: Irvin High School

LOCATION: Throughout Building D


DATE: November 9, 2018

This Environmental Statement is to certify that Building "D" located at Irvin High School in El Paso, Texas was under an asbestos abatement project. The purpose of this project was the removal of the Asbestos Containing Materials (ACM) previously identified in the Building. Negative Pressure Enclosure (NPE) was built on the above mentioned facility. Asbestos abatement was performed in accordance with all applicable Federal and State Regulations and following the Technical Specifications for this specific Project. The Asbestos Abatement Contractor involved in this Project was Border Demolition and Environmental.


The final visual inspection was performed by the Project Manager delegated by the Asbestos Consultant.

Clearance air sampling was conducted, using aggressive methods, after a final visual inspection and results were  $<0.005$  f/cc for all clearance samples, which are below the Environmental Protection Agency (EPA's) and Texas Asbestos Health Protection Rules (TAHPR's) clearance level of 0.01 f/cc. This area therefore can be re-occupied.

Asbestos Project Manager:

  
\_\_\_\_\_  
Oscar E. Ayala

Asbestos Consultant:

  
\_\_\_\_\_  
Juan R. Ayala