



## CLEARANCE STATEMENT

CLIENT: El Paso Independent School District

PROJECT NAME: Jefferson High School

LOCATION: Art Building


DATE: November 29, 2018

This Environmental Statement is to certify that the Art Building located at Jefferson High School in El Paso, Texas was under an asbestos abatement project. The purpose of this project was the removal of Asbestos Containing sheetrock wall texture and sheetrock ceiling texture. A Negative Pressure Enclosure (NPE) was built at above mentioned area. Asbestos abatement was performed in accordance with all applicable Federal and State Regulations and following the Technical Specifications for this specific Project. The Asbestos Abatement Contractor involved in this Project was Border Demolition and Environmental.


The final visual inspection was performed by the Project Manager delegated by the Asbestos Consultant.

Clearance air sampling was conducted, using aggressive methods, after a final visual inspection and results were <0.005 f/cc for all clearance samples, which are below the EPA's clearance level of 0.01 f/cc. This area therefore can be re-occupied.

Asbestos Project Manager:

  
\_\_\_\_\_  
Oscar E. Ayala

Asbestos Consultant:

  
\_\_\_\_\_  
Juan R. Ayala